

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7315-0065:147 Page 1 of 1

**CATEGORY:** Misc. Device/Control Unit Accessories

**LISTEE:** Faraday Inc., 805 S. Maumee St., Tecumseh, MI 49286  
Contact: Steven A. Blohm (517) 423-2111

**DESIGN:** Model APS1 (P/N 12408) Auxiliary Power Supply. Power limited. The unit is intended for use with a separately listed Model \*FW4000 fire alarm control unit (CSFM Listing No. 7165-0065:146) to provide auxiliary power outputs. Refer to listee's data sheet for additional detailed product description, electrical rating and operational considerations.

**RATING:** Primary: 120/240 VAC; and Secondary: 24VDC nominal

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. The power supply must be installed in accordance to NFPA 72, 1993 Edition and must have the battery standby for at least 24 hours.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as auxiliary power supply when used in conjunction with separately listed Model \*FW4000 fire alarm control units.

\*Rev. 07-21-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**  
**Program Manager**